

Why do I need a backflow prevention assembly?

Backflow prevention keeps your drinking water safe by keeping potentially contaminated water within a building's water lines from being drawn back into the potable water system.

What is a backflow prevention assembly?

A backflow prevention assembly is a protective valve typically installed immediately behind the water meter on the customer's side. Backflow preventers allow water to flow from the utility's water main to the customer's water lines behind the meter; however, water or other substances may not flow from the customer's side back out into the utility's water distribution system

Why do I need to have my backflow preventer tested?

Backflow prevention protects the public potable water system from possible contamination. Since backflow preventers contain parts that can break down and wear out it is important to test them to make sure your assemblies are functioning properly.

How often do I need to test my backflow preventer?

Backflow prevention assemblies must be tested annually and the test report forms submitted to Laguna Madre Water District.

Are there any other times a backflow preventer must be tested?

Yes. In addition to the annual testing requirement, backflow prevention assemblies must be tested upon installation, and whenever they are taken apart for cleaning or repairs.

How will I know when my backflow preventer is due to be tested?

Laguna Madre Water District will send out notification letters approximately two to three weeks before your test month are due. You will be assigned an annual due date based on your location so that your backflow prevention assembly will be due for testing at the same time every year. It is your responsibility to have your backflow preventer tested on time whether or not you receive a notification.

How do I get my backflow preventer tested?

A certified backflow prevention assembly tester issued by TCEQ must perform any tests on your assemblies. Backflow prevention assembly testers may test and repair assemblies on firelines only if they are permanently employed by an Approved Fireline Contractor. You may search for certified testers by visiting the Laguna Madre Water District website (www.lmwd.org), selecting "Water" at the top of the page, and choosing "Backflow Prevention". Please note, testing certifications are held by individuals, not by the company for whom they work.

When contacting a certified backflow prevention assembly tester, you should ask if they are approved to test in the Laguna Madre Water District jurisdiction. If they are not, they may contact Jesse Gomez at 956.943.2626 ext. 320 to obtain the necessary paper work and report forms.

How much will it cost to have a backflow preventer tested?

The cost of testing backflow prevention assemblies varies by tester, assembly size, how much time is involved in accessing the assembly, or any repairs that are necessary. Testing larger assemblies or accessing assemblies which may have become buried may cost more. You should discuss prices and services with the tester/testing company.

My backflow preventer failed a test. Who can repair it?

While the individual may be certified to test the backflow prevention assembly, repairs are normally performed by a licensed plumber. Please understand that not all certified testers are licensed plumbers, and not all licensed plumbers are certified testers. You may need to contact a licensed plumber for repairs.

Once a backflow preventer is repaired, it must be retested to ensure proper operation and the test report forms submitted to LMWD for proof of compliance.

Who submits the test report form to the LMWD Backflow Department?

As the owner of backflow preventer the Annual Testing Notice will be sent directly to you, but original test report forms must be submitted to LMWD by the certified tester. Test report forms must be received in our office by the due date stated in your notification letter. You should obtain a copy of the test report from the tester for your records. Test report submission instructions are detailed on the test report form.

Can Laguna Madre Water District recommend a tester or plumber for me?

No, LMWD does not endorse or recommend any backflow tester, company or plumber.

Can Laguna Madre Water District test my backflow preventer for me?

No, LMWD does not perform backflow preventer tests in line of those performed by a certified tester. Any tests performed by LMWD personnel are for field checks or quality control purposes only.

How long does the test take?

The test takes approximately 10-20 minutes per backflow assembly, during which the water must be shut off briefly. You should prepare for a brief water outage while the test is performed and schedule accordingly.

What if a backflow preventer does not get tested?

Laguna Madre Water District will not be able to maintain water service to a property where a required backflow prevention assembly has not been tested and proof of compliance has not been received by our office.